

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

JSC "Chirchik Transformer Plant"

Chirchik city, Tashkent region, Uzbekistan

for the test object:

a three-phase oil-immersed

distribution transformer

Type: TMG-400/6/0,4-U1

Rating: 400 kVA – 6 kV $\pm 2,5\%$ / 400 V – Yyn0 – 50 Hz

manufactured by

JSC "Chirchik Transformer Plant"

Chirchik city, Tashkent region, Uzbekistan

The test object has successfully passed the required type tests of

IEC 60076-1:2011, IEC 60076-2:2011, IEC 60076-3:2013,

IEC 60076-5:2006, IEC 60076-10:2016

The test results are recorded in Certificate No.

2136-20

This Certificate was first issued on 16 September 2020.

KEMA B.V.



Bas Verhoeven

Director, High-Voltage Laboratory

